

COMPANY	SITE	LOCATION	TECHNICIAN	LICENCE NO.	DD-MM-YYYY	HH:MM	APPLIANCE DESC.	APPLIANCE NO.	VISUAL P/F	TAG NO.	EARTH CURRENT	TEST TYPE	ELEC. P/F	IR (M Ohms)	LC (mA)	ER (Ohms)	EC (Ohms)	RCD-0 (mS)	RCD-180 (mS)	COMMENT	PAT TYPE	SERIAL NO.	FoT	NEXT DUE	FOT Code
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	9:59	15 amp lead	1015 P		334286	0	2 P	6.681	0	0.275	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:01	15 amp lead	1001 P		334287	0	2 P	6.652	0	0.28	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:02	15 amp lead	1014 P		334288	0	2 P	6.71	0	0.287	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:24	10 amp lead	1004 P		334289	0	2 P	6.594	0	0.425	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:26	10 amp lead	1018 P		334290	0	2 P	6.681	0	0.486	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:28	10 amp lead	1007 P		334291	0	2 P	6.652	0	0.354	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:30	10 amp lead	1016 P		334292	0	2 P	6.652	0	0.035	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:31	10 amp lead	1019 P		334293	0	2 P	6.623	0	0.332	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:34	10 amp lead	1006 P		334294	0	2 P	6.71	0	0.164	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:11	15 amp rcd	1017 P		334295	0	11 P	6.74	0	0.189	0	18	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:11	15 amp rcd	1017 P		334295	0	11 P	6.74	0	0.189	0	0	27	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:12	15 amp rcd	1017 P		334295	0	11 P	6.681	0	0.189	0	16	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:12	15 amp rcd	1017 P		334295	0	11 P	6.681	0	0.189	0	0	27	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:13	15 amp rcd	1017 P		334295	0	11 P	47.38	0	0.19	0	16	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:13	15 amp rcd	1017 P		334295	0	11 P	47.38	0	0.19	0	0	27	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:14	15 amp rcd	1017 P		334295	0	11 P	6.681	0	0.19	0	17	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:14	15 amp rcd	1017 P		334295	0	11 P	6.681	0	0.19	0	0	27	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:24	no2 makita grind	1022 P		334296	0	6 P	0	0.132	0	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:31	no3 makita grind	1021 P		334297	0	6 P	0	0.132	0	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:38	no3 makita grind	1020 P		334298	0	6 P	0	0.132	0	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:45	no4 makita grind	1023 P		334299	0	6 P	0	0.132	0	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:57	ozito sander	1024 P		334300	0	6 P	0	0.122	0	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	12:05	ozito sander	1025 P		334301	0	6 P	0	0.111	0	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	12:10	ozito sander	1026 P		334302	0	6 P	0	0.129	0	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:15	15 amp rcd	1017 P		334295	0	11 P	6.71	0	0.186	0	18	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:16	15 amp rcd	1017 P		334295	0	11 P	6.681	0	0.185	0	18	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:16	15 amp rcd	1017 P		334295	0	11 P	6.681	0	0.185	0	0	47	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:19	15 amp rcd	1017 P		334295	0	2 P	6.681	0	0.185	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:20	15 amp rcd	1017 P		334295	0	2 P	6.681	0	0.185	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:21	15 amp rcd	1017 P		334295	0	2 P	6.681	0	0.188	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:21	15 amp rcd	1017 P		334295	0	2 P	6.681	0	0.188	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:32	10 amp rcd	1027 P		334303	0	11 P	6.71	0	0.194	0	18	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:32	10 amp rcd	1027 P		334303	0	11 P	6.71	0	0.194	0	0	47	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:33	10 amp rcd	1027 P		334303	0	2 P	6.71	0	0.192	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:34	10 amp rcd	1027 P		334303	0	2 P	6.681	0	0.194	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:34	10 amp rcd	1027 P		334303	0	2 P	6.681	0	0.194	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:35	10 amp rcd	1027 P		334303	0	2 P	6.681	0	0.197	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:41	10 amp rcd	1028 P		334304	0	11 P	6.681	0	0.195	0	20	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:41	10 amp rcd	1028 P		334304	0	11 P	6.681	0	0.195	0	0	66	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:42	10 amp rcd	1028 P		334304	0	2 P	6.681	0	0.194	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:42	10 amp rcd	1028 P		334304	0	2 P	6.71	0	0.196	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:43	10 amp rcd	1028 P		334304	0	2 P	6.681	0	0.197	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:43	10 amp rcd	1028 P		334304	0	2 P	6.71	0	0.198	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:50	10 amp rcd	1029 P		334305	0	11 P	6.71	0	0.198	0	21	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:50	10 amp rcd	1029 P		334305	0	11 P	6.71	0	0.198	0	0	6	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:51	10 amp rcd	1029 P		334305	0	2 P	6.71	0	0.198	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:52	10 amp rcd	1029 P		334305	0	2 P	6.71	0	0.198	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:52	10 amp rcd	1029 P		334305	0	2 P	6.71	0	0.202	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:52	10 amp rcd	1029 P		334305	0	2 P	6.71	0	0.201	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:15	10 amp lead	1030 P		334306	0	2 P	6.594	0	0.388	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:16	10 amp lead	1031 P		334307	0	2 P	6.681	0	0.285	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:19	10 amp lead	1032 P		334308	0	2 P	6.482	0	0.732	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:20	10 amp lead	1033 P		334309	0	2 P	6.681	0	0.453	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:23	10 amp lead	1034 P		3342	0	2 P	6.652	0	0.53	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:57	steves protocol	1035 P		334311	0	1 P	26.69	0	0	0	0	0	0		TRIO STC PRO	12347	3	30/11/2011	Default
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	11:01																			

COMPANY	SITE	LOCATION	TECHNICIAN	LICENCE NO.	DD-MM-YYYY	HH:MM	APPLIANCE DESC.	APPLIANCE NO.	VISUAL P/F	TAG NO.	EARTH CURRENT	TEST TYPE	ELEC. P/F	IR (M Ohms)	LC (mA)	ER (Ohms)	EC (Ohms)	RCD-0 (mS)	RCD-180 (mS)	COMMENT	PAT TYPE	SERIAL NO.	FoT	NEXT DUE	FOT Code	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:37	15 amp rcd	1009 P		334335	0	2 P		6.71	0	0.192	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:38	15 amp rcd	1009 P		334335	0	2 P		6.681	0	0.194	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:39	15 amp rcd	1009 P		334335	0	2 P		6.681	0	0.191	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:39	15 amp rcd	1009 P		334335	0	2 P		6.681	0	0.191	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:43	10 amp rcd	1058 P		334336	0	11 P		6.71	0	0.203	0	17	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:43	10 amp rcd	1058 P		334336	0	11 P		6.71	0	0.203	0	0	27		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:44	10 amp rcd	1058 P		334336	0	2 P		6.681	0	0.202	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:44	10 amp rcd	1058 P		334336	0	2 P		6.681	0	0.203	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:45	10 amp rcd	1058 P		334336	0	2 P		6.681	0	0.201	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:45	10 amp rcd	1058 P		334336	0	2 P		6.681	0	0.201	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:49	10 amp rcd	1003 P		334337	0	11 P		6.681	0	0.201	0	46	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:49	10 amp rcd	1003 P		334337	0	11 P		6.681	0	0.201	0	0	16		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:50	10 amp rcd	1003 P		334337	0	2 P		6.71	0	0.2	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:51	10 amp rcd	1003 P		334337	0	2 P		6.71	0	0.201	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:51	10 amp rcd	1003 P		334337	0	2 P		6.71	0	0.203	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:51	10 amp rcd	1003 P		334337	0	2 P		6.71	0	0.203	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:55	bosch heat gun	1059 P		334338	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:04	ozito heat gun	1060 P		334339	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:11	ozito heat gun	1061 P		334340	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:15	icon rotary sand	1062 P		334341	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:24	triton orb sand	1063 P		334346	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:32	bosch orb sand	1064 P		334342	0	1 P		26.69	0	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	13:09	protocol mixer	1065 P		334343	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	13:20	ozito 9in grind	1066 P		334344	0	1 P		26.69	0	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	8:03	graco markv	1067 P		334349	0	0 P		8.023	0	0.144	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	8:34	atomex gm-60e	1068 P		334350	0	0 P		27.23	0	0.221	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	8:52	black compressor	1069 P		334351	0	0 P		27.23	0	0.1	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:06	blue seiwa pump	1070 P		334352	0	0 P		3.5	0	0.548	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:10	red seiwa pump	1071 P		334353	0	0 P		26.16	0	0.321	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:22	tam pump drill	1072 P		334354	0	6 P		0	0.115	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:29	universal pump	1073 P		334330	0	0 P		26.69	0	0.141	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:39	bosch heat gun	1059 P		334338	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:50	extreme x70 pump	1074 P		334355	0	0 P		27.23	0	0.095	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:07	ryobi power drill	1075 P		334356	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:12	hitachi drill	1002 P		334357	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:18	gmc power saw	1076 P		334358	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:22	dewalt bat charger	1077 P		334359	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:27	milw bat charger	1078 P		334360	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:32	ozito sin grind	1079 P		334361	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:37	bosch hamm drill	1080 P		334362	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:43	metabo hamm drill	1081 P			0	0	0	0	0	0	0	0	0	0		TRIO STC PRO	12347	0	6/09/2011	FAIL
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:45	metabo hamm drill	1081 P		334363	0	1 P		26.69	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:49	milw grind chagr	1082 P		334364	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:55	hilti batt charg	1083 P		334365	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:03	ozito demo break	1084 P		334366	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:10	ozito demo break	1085 P		334367	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:19	hitachi demo bre	1086 P		334368	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:26	diamond core dri	1087 P		334369	0	0 P		26.69	0	0.472	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:31	gmc drop saw	1088 P		334370	0	1 P		27.23	0	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:22	15amp poly trail	1			1	0	2 P		6.652	0	0.285	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:22	15amp poly trail	1089 P			1	0	2 P		6.652	0	0.285	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:24	15amp poly trail	1090 P		0002	3	0	2 P		6.681	0	0.16	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:29	15a rcd poly tra	1091 P			3	0	11 P		6.681	0	0.185	0	16	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:29	15a rcd poly tra	1091 P			3	0	11 P		6.681	0	0.185	0	0	6		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:30	15a rcd poly tra	1091 P			3	0	2 P		6.681	0	0.185	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:30	15a rcd poly tra	1091 P			3	0	2 P		6.652	0	0.185	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons</																										

COMPANY	SITE	LOCATION	TECHNICIAN	LICENCE NO.	DD-MM-YYYY	HH:MM	APPLIANCE DESC.	APPLIANCE NO.	VISUAL P/F	TAG NO.	EARTH CURRENT	TEST TYPE	ELEC. P./F	IR (M Ohms)	LC (mA)	ER (Ohms)	EC (Ohms)	RCD-0 (mS)	RCD-180 (mS)	COMMENT	PAT TYPE	SERIAL NO.	FOt	NEXT DUE	FOT Code
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	9:59	15 amp lead	1015	P	334286	0	2 P	6.681	0	0.275	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:01	15 amp lead	1001	P	334287	0	2 P	6.652	0	0.28	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:02	15 amp lead	1014	P	334288	0	2 P	6.71	0	0.287	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:24	10 amp lead	1004	P	334289	0	2 P	6.594	0	0.425	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:26	10 amp lead	1018	P	334290	0	2 P	6.681	0	0.486	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:28	10 amp lead	1007	P	334291	0	2 P	6.652	0	0.354	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:30	10 amp lead	1016	P	334292	0	2 P	6.652	0	0.035	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:31	10 amp lead	1019	P	334293	0	2 P	6.623	0	0.332	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:34	10 amp lead	1006	P	334294	0	2 P	6.71	0	0.164	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:11	15 amp rcd	1017	P	334295	0	11 P	6.74	0	0.189	0	0	18	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:11	15 amp rcd	1017	P	334295	0	11 P	6.74	0	0.189	0	0	0	27	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:12	15 amp rcd	1017	P	334295	0	11 P	6.681	0	0.189	0	0	16	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:12	15 amp rcd	1017	P	334295	0	11 P	6.681	0	0.189	0	0	0	27	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:13	15 amp rcd	1017	P	334295	0	11 P	47.38	0	0.19	0	0	16	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:13	15 amp rcd	1017	P	334295	0	11 P	47.38	0	0.19	0	0	0	27	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:14	15 amp rcd	1017	P	334295	0	11 P	6.681	0	0.119	0	0	17	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:14	15 amp rcd	1017	P	334295	0	11 P	6.681	0	0.119	0	0	0	27	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:24	no2 makita grind	1022	P	334296	0	6 P	0	0.132	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:31	no1makita grind	1021	P	334297	0	6 P	0	0.132	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:38	no3 makita grind	1020	P	334298	0	6 P	0	0.132	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:45	no4 makita grind	1023	P	334299	0	6 P	0	0.132	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:57	ozito sander	1024	P	334300	0	6 P	0	0.122	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	12:05	ozito sander	1025	P	334301	0	6 P	0	0.111	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	12:10	ozito sander	1026	P	334302	0	6 P	0	0.129	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:15	15 amp rcd	1017	P	334295	0	11 P	6.71	0	0.186	0	0	18	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:16	15 amp rcd	1017	P	334295	0	11 P	6.681	0	0.185	0	0	18	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:16	15 amp rcd	1017	P	334295	0	11 P	6.681	0	0.185	0	0	0	47	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:19	15 amp rcd	1017	P	334295	0	2 P	6.681	0	0.185	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:20	15 amp rcd	1017	P	334295	0	2 P	6.681	0	0.185	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:21	15 amp rcd	1017	P	334295	0	2 P	6.681	0	0.188	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:21	15 amp rcd	1017	P	334295	0	2 P	6.681	0	0.188	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:32	10 amp rcd	1027	P	334303	0	11 P	6.71	0	0.194	0	0	18	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:32	10 amp rcd	1027	P	334303	0	11 P	6.71	0	0.194	0	0	0	47	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:33	10 amp rcd	1027	P	334303	0	2 P	6.71	0	0.192	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:34	10 amp rcd	1027	P	334303	0	2 P	6.681	0	0.194	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:34	10 amp rcd	1027	P	334303	0	2 P	6.681	0	0.197	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:35	10 amp rcd	1027	P	334303	0	2 P	6.681	0	0.198	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:41	10 amp rcd	1028	P	334304	0	11 P	6.681	0	0.195	0	0	20	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:41	10 amp rcd	1028	P	334304	0	11 P	6.681	0	0.195	0	0	0	66	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:42	10 amp rcd	1028	P	334304	0	2 P	6.681	0	0.194	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:42	10 amp rcd	1028	P	334304	0	2 P	6.71	0	0.196	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:43	10 amp rcd	1028	P	334304	0	2 P	6.681	0	0.197	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:43	10 amp rcd	1028	P	334304	0	2 P	6.71	0	0.198	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:50	10 amp rcd	1029	P	334305	0	11 P	6.71	0	0.198	0	0	21	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:50	10 amp rcd	1029	P	334305	0	11 P	6.71	0	0.198	0	0	0	6	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:51	10 amp rcd	1029	P	334305	0	2 P	6.71	0	0.197	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:52	10 amp rcd	1029	P	334305	0	2 P	6.71	0	0.198	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:52	10 amp rcd	1029	P	334305	0	2 P	6.71	0	0.202	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:52	10 amp rcd	1029	P	334305	0	2 P	6.71	0	0.201	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:15	10 amp lead	1030	P	334306	0	2 P	6.594	0	0.388	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:16	10 amp lead	1031	P	334307	0	2 P	6.681	0	0.285	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:19	10 amp lead	1032	P	334308	0	2 P	6.482	0	0.732	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:20	10 amp lead	1033	P	334309	0	2 P	6.681	0	0.453	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:23	10 amp lead	1034	P	3342	0	2 P	6.652	0	0.53	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:57	steves protocol	1035	P	334311	0	1 P	26.69	0	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	11:01	steves protocol	1035	P	334311	0	1 P	27.23	0	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	11:04	festool mixer	1036	P	334313	0	1 P	27.23												

COMPANY	SITE	LOCATION	TECHNICIAN	LICENCE NO.	DD-MM-YYYY	HH:MM	APPLIANCE DESC.	APPLIANCE NO.	VISUAL P/F	TAG NO.	EARTH CURRENT	TEST TYPE	ELEC. P/F	IR (M Ohms)	LC (mA)	ER (Ohms)	EC (Ohms)	RCD-0 (mS)	RCD-180 (mS)	COMMENT	PAT TYPE	SERIAL NO.	FoT	NEXT DUE	FOT Code
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:38	15 amp rcd	1009 P		334335	0	2 P		6.681	0	0.194	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:39	15 amp rcd	1009 P		334335	0	2 P		6.681	0	0.191	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:39	15 amp rcd	1009 P		334335	0	2 P		6.681	0	0.191	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:43	10 amp rcd	1058 P		334336	0	11 P		6.71	0	0.203	0	17	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:43	10 amp rcd	1058 P		334336	0	11 P		6.71	0	0.203	0	0	27		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:44	10 amp rcd	1058 P		334336	0	2 P		6.681	0	0.202	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:44	10 amp rcd	1058 P		334336	0	2 P		6.681	0	0.203	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:45	10 amp rcd	1058 P		334336	0	2 P		6.681	0	0.201	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:45	10 amp rcd	1058 P		334336	0	2 P		6.681	0	0.201	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:49	10 amp rcd	1003 P		334337	0	11 P		6.681	0	0.201	0	46	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:49	10 amp rcd	1003 P		334337	0	11 P		6.681	0	0.201	0	0	16		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:50	10 amp rcd	1003 P		334337	0	2 P		6.71	0	0.2	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:51	10 amp rcd	1003 P		334337	0	2 P		6.71	0	0.201	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:51	10 amp rcd	1003 P		334337	0	2 P		6.71	0	0.203	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:51	10 amp rcd	1003 P		334337	0	2 P		6.71	0	0.203	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:55	bosch heat gun	1059 P		334338	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:04	ozito heat gun	1060 P		334339	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:11	ozito heat gun	1061 P		334340	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:15	icon rotary sand	1062 P		334341	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:24	triton orb sand	1063 P		334346	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:32	bosch orb sand	1064 P		334342	0	1 P		26.69	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	13:09	protocol mixer	1065 P		334343	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	13:20	ozito 9in grind	1066 P		334344	0	1 P		26.69	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	8:03	graco markv	1067 P		334349	0	0 P		8.023	0	0.144	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	8:34	atomex gm-60e	1068 P		334350	0	0 P		7.223	0	0.221	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	8:52	black compressor	1069 P		334351	0	0 P		27.23	0	0.1	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:06	blue seiwa pump	1070 P		334352	0	0 P		3.5	0	0.548	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:10	red seiwa pump	1071 P		334353	0	0 P		26.16	0	0.321	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:22	tam pump drill	1072 P		334354	0	6 P		0	0.115	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:29	universal pump	1073 P		334330	0	0 P		26.69	0	0.141	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:39	bosch heat gun	1059 P		334338	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:50	extreme x70 pump	1074 P		334355	0	0 P		27.23	0	0.095	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:07	ryobi power drill	1075 P		334356	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:12	hitachi drill	1002 P		334357	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:18	gmc power saw	1076 P		334358	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:22	dewalt bat charg	1077 P		334359	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:27	milw bat charger	1078 P		334360	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:32	ozito 5in grind	1079 P		334361	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:37	bosch hamm drill	1080 P		334362	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:43	metabo hamm drill	1081 P		334363	0	1 F		0	0	0	0	0	0		TRIO STC PRO	12347	0	6/09/2011	FAIL
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:45	metabo hamm drill	1081 P		334363	0	1 P		26.69	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:49	milw grind charg	1082 P		334364	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:55	hilti batt charg	1083 P		334365	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:03	ozito demo break	1084 P		334366	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:10	ozito demo break	1085 P		334367	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:19	hitachi demo bre	1086 P		334368	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:26	diamond core dri	1087 P		334369	0	0 P		26.69	0	0.472	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:31	gmc drop saw	1088 P		334370	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:22	15amp poly trail	1		1	0	2 P		6.652	0	0.285	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:22	15amp poly trail	1089 P		1	0	2 P		6.652	0	0.285	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:24	15amp poly trail	1090 P		0002	0	2 P		6.681	0	0.16	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:29	15a rcd poly tra	1091 P		3	0	11 P		6.681	0	0.185	0	16	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:29	15a rcd poly tra	1091 P		3	0	11 P		6.681	0	0.185	0	0	6		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:30	15a rcd poly tra	1091 P		3	0	2 P		6.681	0	0.185	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:30	15a rcd poly tra	1091 P		3	0	2 P		6.652	0	0.185	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:31	15a rcd poly tra	1091 P		3	0	2 P		6.652	0	0.184	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:31	15a rcd poly tra	1091 P		3	0	2 P		6.681	0	0.184	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn																								

COMPANY	SITE	LOCATION	TECHNICIAN	LICENCE NO.	DD-MM-YYYY	HH:MM	APPLIANCE DESC.	APPLIANCE NO.	VISUAL P/F	TAG NO.	EARTH CURRENT	TEST TYPE	ELEC. P./F	IR (M Ohms)	LC (mA)	ER (Ohms)	EC (Ohms)	RCD-0 (mS)	RCD-180 (mS)	COMMENT	PAT TYPE	SERIAL NO.	FoT	NEXT DUE	FOT Code
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	9:59	15 amp lead	1015	P	334286	0	2 P	6.681	0	0.275	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:01	15 amp lead	1001	P	334287	0	2 P	6.652	0	0.28	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:02	15 amp lead	1014	P	334288	0	2 P	6.71	0	0.287	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:24	10 amp lead	1004	P	334289	0	2 P	6.594	0	0.425	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:26	10 amp lead	1018	P	334290	0	2 P	6.681	0	0.486	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:28	10 amp lead	1007	P	334291	0	2 P	6.652	0	0.354	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:30	10 amp lead	1016	P	334292	0	2 P	6.652	0	0.035	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:31	10 amp lead	1019	P	334293	0	2 P	6.623	0	0.332	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	10:34	10 amp lead	1006	P	334294	0	2 P	6.71	0	0.164	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:11	15 amp rcd	1017	P	334295	0	11 P	6.74	0	0.189	0	0	18	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:11	15 amp rcd	1017	P	334295	0	11 P	6.74	0	0.189	0	0	0	27	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:12	15 amp rcd	1017	P	334295	0	11 P	6.681	0	0.189	0	0	16	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:12	15 amp rcd	1017	P	334295	0	11 P	6.681	0	0.189	0	0	0	27	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:13	15 amp rcd	1017	P	334295	0	11 P	47.38	0	0.19	0	0	16	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:13	15 amp rcd	1017	P	334295	0	11 P	47.38	0	0.19	0	0	0	27	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:14	15 amp rcd	1017	P	334295	0	11 P	6.681	0	0.119	0	0	17	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:14	15 amp rcd	1017	P	334295	0	11 P	6.681	0	0.119	0	0	0	27	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:24	no2 makita grind	1022	P	334296	0	6 P	0	0.132	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:31	no1makita grind	1021	P	334297	0	6 P	0	0.132	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:38	no3 makita grind	1020	P	334298	0	6 P	0	0.132	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:45	no4 makita grind	1023	P	334299	0	6 P	0	0.132	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	11:57	ozito sander	1024	P	334300	0	6 P	0	0.122	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	12:05	ozito sander	1025	P	334301	0	6 P	0	0.111	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	30/08/2011	12:10	ozito sander	1026	P	334302	0	6 P	0	0.129	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:15	15 amp rcd	1017	P	334295	0	11 P	6.71	0	0.186	0	0	18	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:16	15 amp rcd	1017	P	334295	0	11 P	6.681	0	0.185	0	0	18	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:16	15 amp rcd	1017	P	334295	0	11 P	6.681	0	0.185	0	0	0	47	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:19	15 amp rcd	1017	P	334295	0	2 P	6.681	0	0.185	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:20	15 amp rcd	1017	P	334295	0	2 P	6.681	0	0.185	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:21	15 amp rcd	1017	P	334295	0	2 P	6.681	0	0.188	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:21	15 amp rcd	1017	P	334295	0	2 P	6.681	0	0.188	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:32	10 amp rcd	1027	P	334303	0	11 P	6.71	0	0.194	0	0	18	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:32	10 amp rcd	1027	P	334303	0	11 P	6.71	0	0.194	0	0	0	47	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:33	10 amp rcd	1027	P	334303	0	2 P	6.71	0	0.192	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:34	10 amp rcd	1027	P	334303	0	2 P	6.681	0	0.194	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:34	10 amp rcd	1027	P	334303	0	2 P	6.681	0	0.198	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:35	10 amp rcd	1027	P	334303	0	2 P	6.681	0	0.197	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:41	10 amp rcd	1028	P	334304	0	11 P	6.681	0	0.195	0	0	20	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:41	10 amp rcd	1028	P	334304	0	11 P	6.681	0	0.195	0	0	0	66	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:42	10 amp rcd	1028	P	334304	0	2 P	6.681	0	0.194	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:42	10 amp rcd	1028	P	334304	0	2 P	6.71	0	0.196	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:43	10 amp rcd	1028	P	334304	0	2 P	6.681	0	0.197	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:43	10 amp rcd	1028	P	334304	0	2 P	6.71	0	0.198	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:50	10 amp rcd	1029	P	334305	0	11 P	6.71	0	0.198	0	0	21	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:50	10 amp rcd	1029	P	334305	0	11 P	6.71	0	0.198	0	0	0	6	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:51	10 amp rcd	1029	P	334305	0	2 P	6.71	0	0.197	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:52	10 amp rcd	1029	P	334305	0	2 P	6.71	0	0.198	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:52	10 amp rcd	1029	P	334305	0	2 P	6.71	0	0.202	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	9:52	10 amp rcd	1029	P	334305	0	2 P	6.71	0	0.201	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:15	10 amp lead	1030	P	334306	0	2 P	6.594	0	0.388	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:16	10 amp lead	1031	P	334307	0	2 P	6.681	0	0.285	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:19	10 amp lead	1032	P	334308	0	2 P	6.482	0	0.732	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:20	10 amp lead	1033	P	334309	0	2 P	6.681	0	0.453	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:23	10 amp lead	1034	P	3342	0	2 P	6.652	0	0.53	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	10:57	staves protocol	1035	P	334311	0	1 P	26.69	0	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	11:01	staves protocol	1035	P	334311	0	1 P	27.23	0	0	0	0	0	0	TRIO STC PRO	12347	3	30/11/2011	Default	
swart n sons	kilburn	workshop	grant w	32618	31/08/2011	11:04	festool mixer	1036	P	334313	0	1 P	27.23												

COMPANY	SITE	LOCATION	TECHNICIAN	LICENCE NO.	DD-MM-YYYY	HH:MM	APPLIANCE DESC.	APPLIANCE NO.	VISUAL P/F	TAG NO.	EARTH CURRENT	TEST TYPE	ELEC. P/F	IR (M Ohms)	LC (mA)	ER (Ohms)	EC (Ohms)	RCD-0 (mS)	RCD-180 (mS)	COMMENT	PAT TYPE	SERIAL NO.	FoT	NEXT DUE	FOT Code
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:37	15 amp rcd	1009 P		334335	0	2 P		6.71	0	0.192	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:38	15 amp rcd	1009 P		334335	0	2 P		6.681	0	0.194	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:39	15 amp rcd	1009 P		334335	0	2 P		6.681	0	0.191	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:39	15 amp rcd	1009 P		334335	0	2 P		6.681	0	0.191	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:43	10 amp rcd	1058 P		334336	0	11 P		6.71	0	0.203	0	17	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:43	10 amp rcd	1058 P		334336	0	11 P		6.71	0	0.203	0	0	27		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:44	10 amp rcd	1058 P		334336	0	2 P		6.681	0	0.202	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:44	10 amp rcd	1058 P		334336	0	2 P		6.681	0	0.203	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:45	10 amp rcd	1058 P		334336	0	2 P		6.681	0	0.201	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:45	10 amp rcd	1058 P		334336	0	2 P		6.681	0	0.201	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:49	10 amp rcd	1003 P		334337	0	11 P		6.681	0	0.201	0	46	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:49	10 amp rcd	1003 P		334337	0	11 P		6.681	0	0.201	0	0	16		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:50	10 amp rcd	1003 P		334337	0	2 P		6.71	0	0.2	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:51	10 amp rcd	1003 P		334337	0	2 P		6.71	0	0.201	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:51	10 amp rcd	1003 P		334337	0	2 P		6.71	0	0.203	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:51	10 amp rcd	1003 P		334337	0	2 P		6.71	0	0.203	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	9:55	bosch heat gun	1059 P		334338	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:04	ozito heat gun	1060 P		334339	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:11	ozito heat gun	1061 P		334340	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:15	icon rotary sand	1062 P		334341	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:24	triton orb sand	1063 P		334346	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	10:32	bosch orb sand	1064 P		334342	0	1 P		26.69	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	13:09	protocol mixer	1065 P		334343	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	1/09/2011	13:20	ozito 9in grind	1066 P		334344	0	1 P		26.69	0	0	0	0	0		TRIO STC PRO	12347	3	1/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	8:03	graco markv	1067 P		334349	0	0 P		8.023	0	0.144	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	8:34	atomex gm-60e	1068 P		334350	0	0 P		27.23	0	0.221	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	8:52	black compressor	1069 P		334351	0	0 P		27.23	0	0.1	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:06	blue seiwa pump	1070 P		334352	0	0 P		3.5	0	0.548	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:10	red seiwa pump	1071 P		334353	0	0 P		26.16	0	0.321	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:22	tam pump drill	1072 P		334354	0	6 P		0	0.115	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:29	universal pump	1073 P		334330	0	0 P		26.69	0	0.141	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:39	bosch heat gun	1059 P		334338	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	9:50	extreme x70 pump	1074 P		334355	0	0 P		27.23	0	0.095	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:07	ryobi power drill	1075 P		334356	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:12	hitachi drill	1002 P		334357	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:18	gmc power saw	1076 P		334358	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:22	dewalt bat chaw	1077 P		334359	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:27	milw bat charger	1078 P		334360	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:32	ozito Sin grind	1079 P		334361	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:37	bosch hamm drill	1080 P		334362	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:43	metabo hamm dril	1081 P			0	1 F		0	0	0	0	0	0		TRIO STC PRO	12347	0	6/09/2011	FAIL
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:45	metabo hamm dril	1081 P		334363	0	1 P		26.69	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:49	milw grind chaw	1082 P		334364	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	10:55	hilti batt chaw	1083 P		334365	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:03	ozito demo break	1084 P		334366	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:10	ozito demo break	1085 P		334367	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:19	hitachi demo bre	1086 P		334368	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:26	diamond core dri	1087 P		334369	0	0 P		26.69	0	0.472	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	6/09/2011	11:31	gmc drop saw	1088 P		334370	0	1 P		27.23	0	0	0	0	0		TRIO STC PRO	12347	3	6/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:22	15amp poly trail	1		1	1		6.652	0	0.285	0	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:22	15amp poly trail	1089 P		1	1		6.652	0	0.285	0	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:24	15amp poly trail	1090 P		2	2		6.681	0	0.16	0	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:29	15a rcd poly tra	1091 P		3	0	11 P		6.681	0	0.185	0	16	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:29	15a rcd poly tra	1091 P		3	0	11 P		6.681	0	0.185	0	0	6		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:30	15a rcd poly tra	1091 P		3	0	2 P		6.681	0	0.185	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:30	15a rcd poly tra	1091 P		3	0	2 P		6.652	0	0.185	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop	grant w	32618	15/09/2011	15:31	15a rcd poly tra	1091 P		3	0	2 P		6.652	0	0.184	0	0	0		TRIO STC PRO	12347	3	15/12/2011	Default
swart n sons	kilburn	workshop																							